

TEST CERTIFICATE

Certificate Number: TC/03/06/05/C1

Date of issue: 11th June 2003

Report Numbers: 529 PCT

Page 1 of 1

This is to certify that samples of: **H107 Mild Steel lift – off hinge**

Manufactured by: **Royde and Tucker at the High Cross Centre in London**

have been successfully type tested according to:

**BS EN 1935: 2002 – Building hardware – single axis hinges
Requirements and test methods**

Classification:

4	7	6	1	1	2	0	13
---	---	---	---	---	---	---	----

by the examination and application of the performance tests for :-

Clause no.	Description
5.1 / 6.4	Initial measurements - Friction < 3Nm
5.2.1 / 7.3.2	Load deformation - 240 Kg
5.2.2 / 7.3.3	Overload - 360 Kg
5.3 / 7.4	Shear strength - N/A
5.4 / 7.5	Endurance - 200,000 cycles
5.5 / 7.1.5	Corrosion resistance - Grade 2 (48 hours, Mild steel hinge)
5.6	Fire resistance doors - Yes (WARRES 118015/A)

Issued by: Paul Duggan, Senior Test Engineer



Date:


17 June 2003

Authorised by: Mr John Saberton Test Laboratory Manager

Date:

23-06-03

for and on behalf of:- Warrington APT Laboratories Ltd



0621